



## Declaration of Conformity

With reference to the request as from our Ref. no. 14628/14/02

The firm: **Eslon BV, Metaalweg 7, 6045 JB Roermond, The Netherlands**

declares under its own responsibility that the products belonging to:

**Mastgoot 125mm Extra gutter system and downpipe system 100mm in the colors brown, white & red (PVC-U)**

meet the following technical requirements of the following standards:

Properties	Standards	Requirements	Test results
<i>Profiles / system</i>			
Hammer impact strength	EN 607 (annex B)	No break	passed
Tensile strength	EN 607 / EN-ISO 6259-1	$\geq 42 \text{ N/mm}^2$	passed
Elongation at break	EN 607 / EN-ISO 6259-1	$\geq 100\%$	passed
Heat reversion	EN 607 / EN-ISO 2505	$\leq 3 \%$	passed
Vicat softening temperature	EN 607 / EN 727	$\geq 75^\circ\text{C}$	passed
Watertightness	EN 607 (annex D)	no leakage	passed
<i>Brackets</i>			
Load bearing capacity	EN 1462 (annex B) (Heavy duty - 750N)	$\leq 5\text{mm}$ permanent deflection & no collapsing	passed

Source: Eslon laboratory tests

Authorized officer : Judith America - Riemens

Title of Authorized officer : QES-officer

Date of issue : January 8, 2014

Signature :



Company seal :

**ESLON B.V.**  
Metaalweg 7  
6045 JB Roermond  
Telefoon 0475-32 28 51  
Telefax 0475-32 82 48



This declaration cancels and replaces any previous releases.

The data listed in this declaration is based on our state of knowledge at the specified date of issue.